

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1591:190 Page 1 of 1

CATEGORY: Misc Device/Control Unit Accessories

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Models 8557-B101 and 8558-B101 addressable open area detector transponder; Models 8557-B103 and 8558-B103 addressable duct detector transponder. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as detector accessories for use with separately listed compatible detectors.

Models 8557-B101, -B103 are intended for connection to Model 8528-X301, -X302 and -X303 (Class B) and 8528-X311, -X312 and -X313 (Class A). Models 8558-B101 and -B103 are intended for connection to Models 8528-X330 (Class B) and 8528-X331 (Class B). These models are listed under CSFM Listing No. 7170-1591:141.

Models 8557-B101 and 8558-B101 can be used with Models 6251B-001 base (CSFM Listing No. 7300-1591:120) and with Model 6250 smoke detector (CSFM Listing No. 7271-1591:110), Model 6270 smoke detector (CSFM Listing No. 7272-1591:112)(Model 8557-B101 only) or Model 291B heat detector (CSFM Listing No. 7270-1591:109).

Models 8557-B103 and 8558-B103 can be used with Model 6260 duct housing (CSFM Listing No. 3240-1591:108), Model 6264 smoke detector (CSFM Listing No. 7271-1591:110) or 6266B smoke detector (CSFM Listing No. 7272-1591:112).

NOTE: Formerly 7300-1388:215

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager